



Diagram af bassircirkulationsarrangement se tegn 240B

- 1
 - 2
 - 3
 - 4
 - 5 GLB-16. Blandedel
 - 6 GLB-16. Varmefladedel 5 rørrækker
 - 7 GLB-16. Ventilator del
 - 8 Cirkulationspumpe Perfecta vario 25
25 W/0,034 #H - 1400 o/min 3x380 V
- se tegn. nr. 240B Entrepri 20 A
- Entrepri 20 B
- Entrepri 20 A

AUTOMATIK fabrikat Billman Entrepri 20 B

- SM : Spjældmotor MBO 220 volt
- MV : Motorventil MV 66 A2 3PG
- KT : Kanaltermostat TACK 4
- P : Potentiometer 39558 /17
- FT : Frosttermostat 270 X/A

STORM HANSEN & Co. A/S
INGENIØRER
GODTHÅBSVEJ 148. F
TLF. 34 43 07

BIKUBENS BOLIG FOND, SKODSBORGVEJ

BLOK 1. SVØMMEBASSIN.
INSTALLATIONSDETALJER, INSTALLATIONSNUM.

MÅL: F:20	DATO: 25.6.71	SIGN.:	KONT.:	SAG: 1284	TEGN.:
REV. A:	B:	C:	D:	E:	F:
DATO: 18.8.71	8.11.71				

ARKITEKTER M.A.A. HALLDOR GUNNLOGSSON & JØRN NIELSEN SNAREGADE 12 1205 KBH. K TELF. BY(0128)5106
 RÅDGIVENDE INGENIØRER B.B. BENDTSEN A/S SUOMISVEJ 3 1927 KBH. V TELF. (01) 35 10 41
 LANDSKABSARKITEKT OLE NØRGÅRDS TEGNESTUE SNAREGADE 12 1205 KBH. K TELF. (01) 12 37 38
 TOTALENTREPRENØR J.SAABYE & O. LERCHE A/S HØVEDKONTOR NYROPSCADE 19 1602 KBH. V TELF. (01) 12 55 50

2407 B